

City of Rome, NY
Water Resource Recovery Facility Improvements Project
RFB 2024-031

Addendum No. 3

TO: All Bidders of Record

Date Issued: January 6, 2025

This addendum shall be part of the Contract Documents as provided in the Agreement for the above-referenced project. **Acknowledge the receipt of this addendum on Page 00400-5 of the Bid Documents for the project. Failure to do so may subject the bidder to disqualification.**

CLARIFICATIONS

1. Some parties have expressed confusion with who is to furnish and install the VFDs (also referred to as VFCs) for the pumps in the main pump station. VFDs are to be furnished by the pump manufacturer under the General Construction Contract and installed under the Electrical Construction Contract. This clarification supersedes any related statements throughout the Contract Documents which may conflict.

QUESTIONS AND ANSWERS

None

CHANGES TO SPECIFICATIONS

None

CHANGES TO DRAWINGS

None

ATTACHMENTS

None